SPRINKLER FLOW TESTING RECORD

Quarterly flow tests from Inspector's Test Connections (ITC's) and annual flow tests from 2-in. drains should be performed on wet-pipe systems. Always contact the alarm monitoring station/Central Security prior to conducting any tests.

Building No.	System No.	Date Tested	Tested by	Type of Test (2-in. or ITC)	Static/Residual Pressure (2-in. drain test only)	Flow Alarm Received (Y/N)