

SPRINKLER VALVE INSPECTION CHECKLIST

Inspector: _____ Date: _____

All sprinkler valves should be inspected for the open position Monthly.
All PIV & WPIV valves should be physically tried Semi-annually.

Valve	Location	Area Controlled	Open	Locked	Shut	Visual	Physical
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							