



### **DELUGE / PREACTION VALVE TRIPPING RECORD**

Deluge and Preaction valves should be automatically tripped, cleaned and reset annually.  
Do not apply grease or pipe compound on valve seats.

<b>System No.</b>	<b>Date Tripped</b>	<b>Tested by</b>	<b>Air Pressure Before Test</b>	<b>Trip Method (SD, HD,PS)</b>	<b>Trip Point Air Pressure</b>	<b>Trip Time</b>

HD = Heat Detectors, SD = Smoke Detectors, PS = Pull Station