Risk Logic®

Risk Logic Inc. • 48 Dimmig Road, Upper Saddle River, NJ 07458 • Phone: (201) 930-0700 • Fax: (201) 930-8795 • www.risklogic.com

Sprinkler Flow Testing Record

- **Quarterly** flow tests from each wet-pipe sprinkler system Inspector's Test Connection *(if mechanical waterflow alarms are provided)*
- **Semi-annual** flow tests from each wet-pipe sprinkler system Inspector's Test Connection *(if vane type flow switches or pressure alarms are provided)*
- **Annual** flow tests from 2-in. drains should be performed on wet-pipe systems.
- Always contact the fire alarm monitoring company/station prior to conducting any tests.

Building No.	System No.	Date Tested	Tested by	Type of Test (2-in. or ITC)	Static/Residual Pressure (2-in. drain test only)	Flow Alarm Received (Y/N)